NSN 5925-01-428-3790

Circuit Breaker - Page 1 of 2



View Online at https://aerobasegroup.com/nsn/5925-01-428-3790

Case Material:

Plastic

Pole Quantity:

2

Mounting Facility Type And Quantity:

4 clip

Maximum Continuous Load Current Rating Per Pole:

1.0 amperes ac all locations

Operating Voltage Type And Rating Per Pole In Volts:

250.0 ac all locations

Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:

2000.0 ac all locations

Circuit Protection Type:

Overcurrent all locations

Trip Release Method:

Magnetic all locations

Trip Release Characteristic:

Time delay all locations

Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:

125.0 all locations

Manual Actuator Type And Quantity:

1 toggle

Actuator Function:

Trip-reset

Actuator Position Designation:

Between pole one and two

Internal Trip Release Configuration:

Series trip all locations

Trip Delay Time In Seconds Per Rated Continuous Current:

4.000 at 200 pct all locations and 18.000 at 200 pct all locations

Inclosure Protection Type For Which Designed:

General purpose

Special Features:

Rocker handle white illumination

Frequency In Hertz:

50.0 all locations or 60.0 all locations

Terminal Type And Quantity:

4 quick disconnect, male

Shelf Life:

N/a

Unit Of Measure:

NSN 5925-01-428-3790

Circuit Breaker - Page 2 of 2

Demilitarization:

No

Fiig:

A030a0

