

View Online at <https://aerobasegroup.com/nsn/5925-01-491-9865>

**End Application:**

Mark 15, or mark4 test set

**Pole Quantity:**

1

**Mounting Facility Type And Quantity:**

1 threaded bushing

**Operating Voltage Type And Rating Per Pole In Volts:**

250.0 ac single location

**Trip Release Method:**

Magnetic-hydraulic single location

**Trip Release Characteristic:**

Time delay single location

**Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:**

3.0 single location

**Reset Method:**

Manual

**Special Features:**

Ncircuit breake type thermal, toggle, 3 apmperes, series trip with auxillary switch, time 11 to 30 seconds, termination type 8-32 90 degrees to each other, 15/32 -32 threaded bushing .320 long double d, silver color

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A030a0