## NSN 5925-01-499-0421

Circuit Breaker - Page 1 of 2



View Online at https://aerobasegroup.com/nsn/5925-01-499-0421 **Body Length:** 5.125 inches **Body Width:** 3.108 inches **Case Material: Plastic** Center To Center Distance Between Terminals Parallel To Length: 3.550 inches **Center To Center Distance Between Terminals Parallel To Width:** 1.026 inches Distance Between Centerlines Of Mounting Facilities Parallel To Body Length: 2.750 inches Distance Between Centerlines Of Mounting Facilities Parallel To Body Width: 1.026 inches **End Application:** Space lift **Boss Height:** 0.220 inches **Mounting Surface To Terminal End Distance:** 3.550 inches **Pole Quantity:** 3 **Mounting Facility Type And Quantity:** 6 threaded hole **Maximum Continuous Load Current Rating Per Pole:** 100.0 amperes ac all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac all locations Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 1000.0 ac all locations **Circuit Protection Type:** Overcurrent all locations **Trip Release Method:** Magnetic all locations **Trip Release Characteristic:** Time delay all locations **Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:** 125.0 all locations **Reset Method:** 

Manual

**Main Contact Tripping Mechanism Type:** 

Trip free

## **NSN 5925-01-499-0421** Circuit Breaker - Page 2 of 2



Manual Actuator Type And Quantity:
3 toggle
Actuator Function:
Trip-reset
Actuator Position Designation:
At each pole
External Actuator Linkage Arrangement:
One, two, and three linked
Internal Trip Release Configuration:
Series trip all locations
Thread Size:
0.138 inches
Trip Delay Time In Seconds Per Rated Continuous Current:
3.000 at 200 pct all locations and 15.000 at 200 pct all locations
Special Features:
Breaker magnetic
Frequency In Hertz:
50.0 all locations or 60.0 all locations
Thread Series Designator:
Unc
Terminal Type And Quantity:
6 threaded stud
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
Yes - demil/mli
Fiig:
A030a0