NSN 5925-01-503-1815

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-503-1815

Polo Quantitus	
Pole Quantity:	
Manustina Facility Tyr	and Occupation
Mounting Facility Typ	e And Quantity:
6 unthreaded hole	
Maximum Continuous	s Load Current Rating Per Pole:
0.500 amperes ac all lo	ocations
Operating Voltage Ty	pe And Rating Per Pole In Volts:
250.0 ac all locations	
Maximum Interrupting	g Capacity Current Type And Rating Per Pole In Amps:
5000.0 ac all locations	
Trip Release Method:	
Magnetic all locations	
Reset Method:	
Manual	
Frequency In Hertz:	
400.0 all locations	
Shelf Life:	
N/a	
Unit Of Measure:	
Demilitarization:	
No	
Fiig:	