NSN 5925-01-525-1392

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-525-1392

Pole Quantity:
3
Trip Release Method:
Magnetic all locations
Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:
125.0 all locations
Reset Method:
Electric
Internal Trip Release Configuration:
Series trip w/auxiliary load terminal all locations
Special Features:
Radar 3d band d long range
Frequency In Hertz:
50.0 all locations
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0