NSN 5925-01-532-6749

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-532-6749

_		17.14			D	_	-		
Οþ	perating	Voltage	Type	Ana	Rating	Per	Pole	ın	voits:

600.0 ac all locations and 250.0 dc all locations

Trip Release Method:

Thermal-magnetic all locations

Reset Method:

Manual

Actuator Function:

Trip-reset

Actuator Position Designation:

At pole two

Frequency In Hertz:

50.0 all locations or 60.0 all locations

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

A030a0