## NSN 5925-01-542-4741

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-542-4741

Dala Constitue
Pole Quantity:
2
Maximum Continuous Load Current Rating Per Pole:
5.0 amperes dc single location
Operating Voltage Type And Rating Per Pole In Volts:
125.0 dc single location
Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:
50.0 dc single location
Circuit Protection Type:
Overcurrent single location
Trip Release Method:
Magnetic single location
Trip Release Characteristic:
Instantaneous single location
Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:
125.0 single location
Reset Method:
Electric
Special Features:
One toggle handle per unit; sealed toggle with bushing mounting
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0