

View Online at <https://aerobasegroup.com/nsn/5925-01-572-6269>

End Application:

Switchboard, p/n 389-01-010

Pole Quantity:

3

Special Features:

Generator circuit breaker; 3200a, ansi, masterpact nw 85ka consisting of square d masterpact (r), drawout circuit breaker, model nw32h2, 3 pole ansi c37, rated 3200 amps, 3000 amp sensor plug; ul type e rating plug; micrologic (r) trip unit, type 5.0p with zone selective protection (lsi), no ground fault, 12 auxiliary contacts w/2pcm module, spring charging motor, 100-130 vac, shunt trip, 24-30vac/vdc, closing coil, 24-30vac/vdc, adj time delay undervoltage trip 100-130vac, padlockable pushbutton cover, no second overcurrent trip, terminations for drawout breaker

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

A030a0