# NSN 5925-01-604-1989

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-604-1989

#### **End Application:**

Panel, gov local opera p/n 599 031-775814

## Pole Quantity:

2

## Maximum Continuous Load Current Rating Per Pole:

4.0 amperes ac single location

## **Operating Voltage Type And Rating Per Pole In Volts:**

480.0 ac single location

#### **Circuit Protection Type:**

Overvoltage single location

#### **Trip Release Method:**

Magnetic single location

#### Frequency In Hertz:

60.0 single location

#### Shelf Life:

N/a

#### Unit Of Measure:

--

#### Demilitarization:

No

# Fiig:

A030a0