## NSN 5925-01-646-3987

Circuit Breaker - Page 1 of 1

03

N/a

---

No



View Online at https://aerobasegroup.com/nsn/5925-01-646-3987

## **Pole Quantity:** Maximum Continuous Load Current Rating Per Pole: 2000.0 amperes ac all locations **Operating Voltage Type And Rating Per Pole In Volts:** 500.0 ac all locations Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 1320.0 ac all locations **Circuit Protection Type:** Overcurrent all locations Auxiliary Trip Coil Voltage Type And Rating In Volts: 120.0 ac all locations **Trip Release Characteristic:** Time delay all locations **Ultimate Trip Time Per Pole In Seconds:** 2.0 and 24.0 all locations **Reset Method:** Electric and manual Internal Trip Release Configuration: Shunt trip all locations **Frequency In Hertz:** 60.0 all locations **Specification Data:** 81349-mil-dtl-17587c government specification and 81349-mil-dtl-17587/3 government specification Shelf Life: Unit Of Measure: **Demilitarization:** Fiig: A030a0