

View Online at <https://aerobasegroup.com/nsn/5930-00-553-7122>

**Distance Between Mounting Facility Centers:**

0.812 inches

**Operating Temperature Rating:**

Between -190.0 degrees fahrenheit and 210.0 degrees fahrenheit

**Mounting Method:**

Flange

**Contact Action Stimulus:**

Increase

**Mounting Facility Pattern:**

Two position in-line

**Nonpile-up Contact Arrangement:**

1 pole, single throw, normally closed, momentary action

**Terminal Type:**

Tab, solder lug

**Contact Adjustability:**

Actuation point not adjustable

**Contact Stimulus Rating:**

20.00 differential point degrees fahrenheit and 200.00 actuation point degrees fahrenheit

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A048b0