

View Online at <https://aerobasegroup.com/nsn/5940-01-524-9628>

**Mounting Hole Diameter:**

0.250 inches

**Body Style:**

Barrier type

**Terminal Row Quantity:**

2

**Center To Center Distance Between Terminals:**

0.690 inches

**Distance Between Terminal Row Centers:**

0.630 inches

**Board Construction:**

Hollow construction with insulated strip

**Center To Center Distance Between Mounting Facilities Parallel To Length:**

6.190 inches

**Center To Center Distance Between Mounting Facilities Parallel To Width:**

0.630 inches

**Boardlength:**

6.620 inches

**Boardwidth:**

1.810 inches

**Boardheight:**

0.940 inches

**Board Height Excluding Terminals:**

0.750 inches

**Base Thickness:**

0.440 inches

**End Application:**

Static exciter/regulator panel assembly, 60 hz lpd-4, sse, 125-17 kw

**Current Rating In Amps:**

50.0

**Mounting Facility Type And Quantity:**

4 unthreaded hole

**Terminal Connecting Link Quantity:**

10 single

**Nonfeedthru Terminal Type:**

597 single

**Terminal Connecting Link Type:**

18 single

**Nonfeedthru Terminal Quantity:**

8 single

**Terminal Pattern Arrangement:**

Multi-row

**Terminal Design:**

Linked nonfeedthru

**Product Name:**

Kulka 603 gp series stud terminal block

**Special Features:**

Studs extend 0.50 inch above base; threads are 10-32 nf

**Material:**

Plastic phenolic board

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fig:**

A011b0