NSN 5945-00-561-1396

Electromagnetic Relay - Page 1 of 2



View Online at https://aerobasegroup.com/nsn/5945-00-561-1396

Thread Class: 2b second mounting facility **Thread Direction:** Right-hand second mounting facility **Overall Length:** 3.250 inches Center To Center Distance Between Mounting Facilities Parallel To Length: 1.750 inches second mounting facility **Overall Height:** 5.820 inches **Overall Width:** 3.320 inches **Case Material: Plastic Environmental Protection:** Dustproof **Unthreaded Mounting Hole Diameter:** 0.199 inches first mounting facility Center To Center Distance Between Mounting Facilities Parallel To Height: 0.500 inches second mounting facility **Fragility Factor:** Moderately rugged **Contact Material:** Silver Winding Quantity: **Purpose For Which Designed:** General **Coil Quantity: Duty Type:** Continuous **Arc Quenching Method:** Air **Mounting Facility Type And Quantity:** 6 unthreaded hole first mounting facility Storage Type: General purpose warehouse **Cubic Measure:** 62.798 cubic inches

Thready Qty Per Inch (tpi): 32 second mounting facility

NSN 5945-00-561-1396

A03300

Electromagnetic Relay - Page 2 of 2



Thread Size:
0.164 inches second mounting facility
Mounting Facility Pattern:
Rectangular second mounting facility
Nonpile-up Main Contact Arrangement:
4 pole, double throw, one position momentary
Time Delay:
0.10 seconds adjustable operate time and 1.00 seconds adjustable operate time
Operating Voltage Rating And Type At Specificationified Temp:
250.0 volts dc 25 degrees celsius single winding
Main Contact Load Current Rating At Maximum Rated Voltage:
10.0 amperes ac resistive load and 15.0 amperes dc resistive load
Main Contact Maximum Voltage Rating In Volts:
240.0 ac and 30.0 dc
Energizing Element Power Rating:
8.0 watts
Precious Material And Location:
Contacts silver
Precious Material:
Silver
Thread Series Designator:
Unc second mounting facility
Terminal Type And Quantity:
14 screw all functions
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig: