

View Online at <https://aerobasegroup.com/nsn/5950-00-168-4065>

**Reliability Indicator:**

Not established

**Center To Center Distance Between Mounting Facilities Parallel To Length:**

2.360 inches single mounting facility single center group and 2.390 inches single mounting facility single center group

**Center To Center Distance Between Mounting Facilities Parallel To Width:**

0.735 inches single mounting facility single center group and 0.765 inches single mounting facility single center group

**Mounting Hole Diameter:**

0.143 inches single group and 0.172 inches single group

**Frequency Rating:**

400.0 hertz single component

**Input-output Phase Relationship:**

Three phase to three phase single component

**Transformer Winding Connection Type:**

Wye-delta

**Body Length:**

3.000 inches

**Body Width:**

1.250 inches

**Body Height:**

3.000 inches

**Inclosure Type:**

Fully enclosed

**Mounting Facility Quantity:**

3 single group

**Mounting Method:**

Unthreaded hole single group

**Winding Function And Quantity:**

1 primary single component and 1 secondary single component

**Winding Operating Current:**

250.0 milliamperes ac single component single secondary

**Winding Operating Voltage:**

115.00 ac volts single component single secondary

**Test Data Document:**

19133-902598 drawing (this is the basic governing drawing, such as a contractor drawing, original equipment manufacturer drawing, etc.; excludes any specification, standard or other document that may be referenced in a basic governing drawing)

**Terminal Type And Quantity:**

7 threaded stud

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A058b0