# NSN 5950-00-631-3071

Power Transformer - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5950-00-631-3071

A1	T- 01	D:-1	D = 1= =	NA	F11141	Dans Hall	
Center	i o Center	Distance	Between	Mounting	Facilities	Parallel 10	o Lenatn:

7.250 inches single mounting facility single center group

# **Center To Center Distance Between Mounting Facilities Parallel To Width:**

5.250 inches single mounting facility single center group

**Mounting Slot Width:** 

0.312 inches single group

Frequency Rating:

60.0 hertz single component

## Input-output Phase Relationship:

Single phase to single phase single component

Inclosure Type:

Open

## **Mounting Facility Quantity:**

4 single group

#### **Mounting Method:**

Flange single group and slot single group

## **Winding Function And Quantity:**

2 primary single component and 1 secondary single component

# **Winding Power Rating:**

3.0 k1lovolt-amperes single component single secondary

# **Winding Operating Voltage:**

460.00 ac pounds per hour wet single component 1st primary

Shelf Life:

N/a

**Unit Of Measure:** 

--

Demilitarization:

No

Fiig:

A058b0