NSN 5950-00-911-7015

Reactor - Page 1 of 2



View Online at https://aerobasegroup.com/nsn/5950-00-911-7015

Reliability Indicator:
Not established
Center To Center Distance Between Mounting Facilities Parallel To Length:
3.000 inches single mounting facility single center group
Center To Center Distance Between Mounting Facilities Parallel To Width:
2.437 inches single mounting facility single center group
Inductance Type:
Swinging
Inductance Rating:
8.20 millihenries single component 1st winding and 80.00 millihenries single component 1st winding
Body Length:
3.375 inches
Body Width:
3.937 inches
Body Height:
5.250 inches
Winding Quantity:
2 single component
Inclosure Type:
Hermetically sealed
Mounting Facility Quantity:
4 single group
Mounting Method:
Threaded stud single group
Rating Method:
Electrical single component all winding
Thready Qty Per Inch (tpi):
32 single group
Thread Size:
0.164 inches single group
Winding Operating Current:
4.8 amperes dc single component 1st winding and 8.0 amperes dc single component 1st winding
Dc Resistance Rating In Ohms:
0.150 single component 1st winding
Criticality Code Justification:
Feat
Special Features:
Ref number differnetiating material will be iaw naval inventory control point hx quality control, manufacturing and testing specification
available at the dla icp
Thread Series Designator:

Terminal Type And Quantity:

Unc single group

4 standoff insulator

NSN 5950-00-911-7015

Reactor - Page 2 of 2



_					
•	n	0 1	•	12	e:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

A058b0