NSN 5950-00-914-1971

Reactor - Page 1 of 2



<u> </u>
View Online at https://aerobasegroup.com/nsn/5950-00-914-1971
Reliability Indicator:
Not established
Center To Center Distance Between Mounting Facilities Parallel To Length:
3.750 inches single mounting facility single center group
Center To Center Distance Between Mounting Facilities Parallel To Width:
3.000 inches single mounting facility single center group
Overall Height:
4.000 inches
Inductance Type:
Fixed
Inductance Rating:
2.00 millihenries single component single winding
Frequency Rating:
60.0 hertz single component
Body Length:
4.656 inches
Body Width:
4.000 inches
Body Height:
3.438 inches
Maximum Operating Temp:
65.0 degrees celsius
Winding Quantity:
1 single component
Inclosure Type:
Open
Mounting Facility Quantity:
4 single group
Mounting Method:

Threaded stud single group

Rating Method:

Electrical single component single winding

Thready Qty Per Inch (tpi):

32 single group

Thread Size:

0.164 inches single group

Winding Operating Current:

18.0 amperes dc single component single winding

Dc Resistance Rating In Ohms:

0.033 single component single winding

Thread Series Designator:

Unc single group

NSN 5950-00-914-1971

Reactor - Page 2 of 2



Termina	I Type	And C	Quantity:
ı Cı illili	IIVDE	Allu V	zuannıv.

2 tab, solder lug

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

A058b0