# NSN 5950-01-024-6136

Power Transformer - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5950-01-024-6136

Center 1	To Center	Distance	Retween	Mounting	Facilities	<b>Parallel To</b>	I ength:
Center	IO CEIILEI	Distance	DerMeeli	WOULTHIA	i acililies	raialiei io	Lenuni.

6.030 inches single mounting facility single center group

## **Center To Center Distance Between Mounting Facilities Parallel To Width:**

5.500 inches single mounting facility single center group

## **Mounting Hole Diameter:**

0.438 inches single group

### Frequency Rating:

57.0 hertz single component and 440.0 hertz single component

### Input-output Phase Relationship:

Single phase to single phase single component

## Winding Shielding Method:

Internal shield grounded to inclosure and core single component

### **Body Length:**

11.380 inches

## **Body Width:**

9.250 inches

# **Body Height:**

7.810 inches

# **Inclosure Type:**

Fully enclosed

# **Mounting Facility Quantity:**

16 single group

### **Mounting Method:**

Flange single group and unthreaded hole single group

## **Winding Function And Quantity:**

1 primary single component and 1 secondary single component

# **Winding Operating Current:**

970.0 milliamperes ac single component single secondary

### **Terminal Type And Quantity:**

6 tab, solder lug

## Shelf Life:

N/a

## **Unit Of Measure:**

### **Demilitarization:**

No

## Fiig:

A058b0