## NSN 5950-01-275-0862

Reactor-transformer - Page 1 of 2



View Online at https://aerobasegroup.com/nsn/5950-01-275-0862 **Reliability Indicator:** Not established **Overall Length:** 11.120 inches Center To Center Distance Between Mounting Facilities Parallel To Length: 11.000 inches 2nd mounting facility single center group **Center To Center Distance Between Mounting Facilities Parallel To Width:** 2.594 inches 2nd mounting facility single center group **Overall Height:** 6.430 inches **Overall Width:** 4.840 inches **Mounting Hole Diameter:** 0.312 inches 1st group and 0.319 inches 1st group **Primary To Secondary Turn Ratio:** 1 to 17 2nd component **Distance Between Mounting Facility Centers:** 2.594 inches 1st mounting facility single center group **Inclosure Type:** Fully enclosed **Mounting Facility Quantity:** 6 2nd group **Mounting Method:** Unthreaded hole 1st group **Rating Method:** Electrical all components all winding **Thread Size:** 0.250 inches 2nd group **Winding Operating Current:** 300.0 amperes ac 2nd component single secondary **Winding Operating Voltage:** 16000.00 ac volts 2nd component single secondary **Thread Series Designator:** Unc 2nd group **Terminal Type And Quantity:** 12 threaded stud Shelf Life: N/a **Unit Of Measure:** 

**Demilitarization:** 

No

## NSN 5950-01-275-0862

Reactor-transformer - Page 2 of 2



Fiig:

A058b0