# NSN 6115-00-407-8313

Generator Stator - Page 1 of 1

View Online at https://aerobasegroup.com/nsn/6115-00-407-8313



# **Terminal Quantity:**

12

**Terminal Type:** 

Any acceptable

# Inside Diameter:

Between 15.267 inches and 15.273 inches

#### **Overall Diameter:**

21.625 inches

#### **End Application:**

6115-00-118-1253

# Main Pole Quantity:

2

### Housing In Accordance With Nema Standard:

Not provided

Housing:

#### Provided

End Bracket Mounting:

Provided

## End Item Mounting Facility For Which Designed:

Generator

#### Shelf Life:

N/a

#### Unit Of Measure:

---

## Demilitarization:

No

#### Fiig:

T321-b