NSN 6625-01-128-8385

Circuit Breaker Test Set - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/6625-01-128-8385

Special Features:

Nain: test set, trip device; delivers a controlled current to uut equivalent to thesecondary current of the breaker curr	ent transformer	s; rating:
0.6 kva continuous; oper power: 120 vac, 60 hz, 1 phase; output: reactor 0-120 v at 10 amps, transformer 0-10 v a	at 30 amps; inc	ludes ac
ammeter, dc voltmeter & digital timer; housed in formica enclosure w/ removable, hinged cover & carrying handle; 1	5 in. H, 17 in. V	V, 10 in.

Dp; 50 lbs

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

A23800