## NSN 6635-01-576-3126

Fiig: T361-f

Compressed Gas Cylinder Test Stand - Page 1 of 1

View Online at https://aerobasegroup.com/nsn/6635-01-576-3126



**Mounting Type:** Floor **Current Type:** Ac **Product Name:** Hydrostatic test console Voltage In Volts: 110.0 **Special Features:** 65in h x 24in w x 18in l; requires 10cfm at 100psig and water supply **Functional Description:** Used for low volume cylinder requalification. Ideal for fire extinguishers, scba, and scuba cylinders for up to 10, 000psi **Reference Data And Literature:** Galiso manual 21-11-1098 Shelf Life: N/a **Unit Of Measure:** Demilitarization: Yes - demil/mli