

View Online at <https://aerobasegroup.com/nsn/6680-01-440-8429>

**End Application:**

Used on ansul r-102 restaurant fire suppression system

**Special Features:**

Test kit assembly is required to test regulator setting and nitrogen flow during 12 yr maintenance exams

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fig:**

T228-a