

View Online at <https://aerobasegroup.com/nsn/9140-00-242-6748>

**Minimum Burning Test Time In Hours:**

16.0

**Fuel Grade Classification:**

Kerosene 2k

**Distillation Point Percentage At Maximum Temp:**

205.0 degrees c at 10.0 percent and 300.0 degrees c at final boiling point

**Nato Code Number:**

F58

**Copper Corrosion Classification Number:**

3

**Minimum Flash Point And Test Method:**

38.0 degrees celsius tag closed cup

**Supply Classification:**

Bulk

**Test Data Document:**

81346-astm-d-3699 specification (includes engineering type bulletins, brochures, etc., that reflect specification type data in specification format; excludes commercial catalogs, industry directories, and similar trade publications, reflecting general type data on certain environmental and performance requirements and test conditions that are shown as "typical", "average", "", etc.).

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A090a0